

# 2008 WATER QUALITY REPORT FOR Iowa Falls Water Department

This report contains important information regarding the water quality in our water system. The source of our water is groundwater. Our groundwater is drawn from the Mississippian and Devonian aquifer(s).

Our water quality testing shows the following results:

CONTAMINANT	MCLG	MCL	DETECTED LEVEL	DATE SAMPLED	RANGE OF DETECTION	VIOLATION	SOURCE
Lead (ppb)	0	AL=15	6 1 sample exceeded	6-1-05 to 9-30-07	0-72	No	Corrosion of household plumbing systems; erosion of natural deposits
Chlorine (ppm)	MRDLG=4.0	MRDL=4.0	1.45	RAA	1.39-1.55	No	Water additive used to control microbes
Copper (ppm)	1.3	AL=1.3	0.214	6-1-05 to 9-30-07	0 – 0.312	No	Corrosion of household plumbing systems; Erosion of natural deposits
TTHM (ppb) [Total trihalomethanes]	N/A	80	35.2	7-14-08	NA	No	By-products of drinking water disinfection
Fluoride (ppm)	4	4	1.15	September 2008	0.95 – 1.15	No	Water additive which promotes strong teeth; Erosion of natural deposits; Discharge from fertilizer and aluminum factories

## PINE STREE PLANT

CONTAMINANT	MCLG	MCL	DETECTED LEVEL	DATE SAMPLED	RANGE OF DETECTION	VIOLATION	SOURCE
Arsenic (ppb)	0	10	2.0	7/20/04	NA	No	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronic production wastes
Barium (ppm)	2	2	0.22	7/20/04	NA	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Sodium (ppm)	N/A	N/A	14.2	7/14/08	NA	No	Erosion of natural deposits; Added to water during treatment process
Nitrate [as N] (ppm)	10	10	0.8	2008	NA	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Combined radium (pCi/L)	0	5	1.5	7-14-08	NA	No	Erosion of natural deposits

## ELK RUN PLANT

CONTAMINANT	MCLG	MCL	DETECTED LEVEL	DATE SAMPLED	RANGE OF DETECTION	VIOLATION	SOURCE
Arsenic (ppb)	0	10	1.0	7/20/04	NA	No	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronic production wastes
Barium (ppm)	2	2	0.24	7/20/04	NA	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits

Sodium (ppm)	N/A	N/A	11.5	7/14/08	NA	No	Erosion of natural deposits; Added to water during treatment process
Alpha emitters (pCi/L)	0	15	3	10/2/08	NA	No	Erosion of natural deposits
Combined radium (pCi/L)	0	5	1.5	7/14/08	NA	No	Erosion of natural deposits

Note: Contaminants with dates indicate results from the most recent testing done in accordance with regulations.

## DEFINITIONS

- Maximum Contaminant Level (MCL) – The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- Maximum Contaminant Level Goal (MCLG) -- The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- ppb -- parts per billion.
- ppm -- parts per million.
- pCi/L – picocuries per liter
- N/A – Not applicable
- ND -- Not detected
- RAA – Running Annual Average
- Action Level (AL) – The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
- Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

## GENERAL INFORMATION

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water posed a health risk. More information about contaminants or potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Iowa Falls Water Department is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

## CONTAMINANT VIOLATIONS

No Violations for 2008.

## ADDITIONAL HEALTH INFORMATION

Infants and young children are typically more vulnerable to lead in drinking water than the general population. It is possible that lead levels at your home may be higher than at other homes in the community as a result of materials used in your home's plumbing. If you are concerned about elevated lead levels in your home's water, you may wish to have your water tested and flush your tap for 30 seconds to 2 minutes before using tap water. Additional information is available from the Safe Drinking Water Hotline (800-426-4791).

## **SOURCE WATER ASSESSMENT INFORMATION**

The Iowa Falls water supply obtains its water from the Mississippian and Devonian aquifer. The Mississippian and Devonian aquifer was determined to be highly susceptible to contamination because the characteristics of the aquifer and overlying materials allow contaminants to move through the aquifer fairly quickly. The wells will be most susceptible to activities such as dry cleaners, gas stations, industrial sites, and municipal wastewater dischargers. A detailed evaluation of your source water was completed by the IDNR, and is available from Iowa Falls at City Hall at 315 Stevens Street.

## **OTHER INFORMATION**

Our water utility is making every effort to protect the water system from potential security threats. You, as customers, can also help. If you see any suspicious activity near the water tower, treatment plant, wells or fire hydrants, please contact the Police Department at 641-648-6464. We appreciate your assistance in protecting the water system.

## **CONTACT INFORMATION**

For questions regarding this information, please contact Scott Peden, Water Superintendent at 641-648-3714 during the following hours: 7:00 am to 3:30 pm.

Decisions regarding the water system are made at the city council meetings held on the third Monday at 6:30 p.m. at Barlow Library, 921 Washington Avenue and are open to the public.

This report will not be mailed but may be picked up at the City Hall at 315 Stevens Street or Barlow Library at 921 Washington Avenue.